

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 4)**

Water Level of the accumulated water (at 7:00 on September 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 854 mm (844 mm decrease since 7:00 on September 3)	O.P.+ 3,190 mm (90 mm decrease since 7:00 on September 3)	—
	Water level of Turbine Building	O.P.+ 2,580 mm (38 mm increase since 7:00 on September 3)	O.P.+ 3,124 mm (18 mm increase since 7:00 on September 3)	O.P.+ 3,261 mm (4 mm decrease since 7:00 on September 3)	O.P.+ 3,194 mm (14 mm increase since 7:00 on September 3)
	Water level of Reactor Building	O.P.+ 4,914 mm (18 mm decrease since 7:00 on September 3)	O.P.+ 3,267 mm (19 mm increase since 7:00 on September 3)	O.P.+ 3,395 mm (No change since 7:00 on September 3)	O.P.+ 3,146 mm (8 mm increase since 7:00 on September 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,861 mm (Increase from initial level:6,078 mm, 129 mm decrease since 7:00 on September 3) O.P.+ 2,651 mm (Increase from initial level:3,377 mm, 170 mm increase since 7:00 on September 3) O.P.+ 4,385 mm (Water level from floor:589 mm, 1 mm increase since 7:00 on September 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 15:48 on September 3 to 7:58 on September 4)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 15:48 on September 3 to 7:58 on September 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:09 on September 2 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:24 on September 3 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.