

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 5)**

Water Level of the accumulated water (at 7:00 on September 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 964 mm (110 mm increase since 7:00 on September 4)	O.P.+ 3,190 mm (No change since 7:00 on September 4)	—
	Water level of Turbine Building	O.P.+ 2,617 mm (37 mm increase since 7:00 on September 4)	O.P.+ 3,136 mm (12 mm increase since 7:00 on September 4)	O.P.+ 3,235 mm (26 mm decrease since 7:00 on September 4)	O.P.+ 3,203 mm (9 mm increase since 7:00 on September 4)
	Water level of Reactor Building	O.P.+ 4,905 mm (9 mm decrease since 7:00 on September 4)	O.P.+ 3,281 mm (14 mm increase since 7:00 on September 4)	O.P.+ 3,373 mm (22 mm decrease since 7:00 on September 4)	O.P.+ 3,152 mm (6 mm increase since 7:00 on September 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,741 mm (Increase from initial level:5,958 mm, 120 mm decrease since 7:00 on September 4) O.P.+ 2,730 mm (Increase from initial level:3,456 mm, 79 mm increase since 7:00 on September 4) O.P.+ 4,386 mm (Water level from floor:590 mm, 1 mm increase since 7:00 on September 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:14 on September 4)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:33 on September 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:09 on September 2 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:24 on September 3 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.