

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 6)**

Water Level of the accumulated water (at 7:00 on September 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,048 mm (84 mm increase since 7:00 on September 5)	O.P.+ 3,160 mm (30 mm decrease since 7:00 on September 5)	—
	Water level of Turbine Building	O.P.+ 2,626 mm (9 mm increase since 7:00 on September 5)	O.P.+ 3,094 mm (42 mm decrease since 7:00 on September 5)	O.P.+ 3,188 mm (47 mm decrease since 7:00 on September 5)	O.P.+ 3,199 mm (4 mm decrease since 7:00 on September 5)
	Water level of Reactor Building	O.P.+ 4,883 mm (22 mm decrease since 7:00 on September 5)	O.P.+ 3,253 mm (28 mm decrease since 7:00 on September 5)	O.P.+ 3,320 mm (53 mm decrease since 7:00 on September 5)	O.P.+ 3,160 mm (8 mm increase since 7:00 on September 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,872 mm (Increase from initial level:6,089 mm, 131 mm increase since 7:00 on September 5) O.P.+ 2,565 mm (Increase from initial level:3,291 mm, 165 mm decrease since 7:00 on September 5) O.P.+ 4,387 mm (Water level from floor:591 mm, 1 mm increase since 7:00 on September 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Currently being transferred (Since 6:09 on September 6)	→Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 15:34 on September 5)	→Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 15:33 on September 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:09 on September 2 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:24 on September 3 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.