

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 8)**

Water Level of the accumulated water (at 7:00 on September 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,188 mm (296 mm decrease since 7:00 on September 7)	O.P.+ 3,120 mm (No change since 7:00 on September 7)	—
	Water level of Turbine Building	O.P.+ 2,470 mm (46 mm increase since 7:00 on September 7)	O.P.+ 3,109 mm (40 mm increase since 7:00 on September 7)	O.P.+ 3,186 mm (10 mm increase since 7:00 on September 7)	O.P.+ 3,183 mm (6 mm decrease since 7:00 on September 7)
	Water level of Reactor Building	O.P.+ 5,097 mm (72 mm increase since 7:00 on September 7)	O.P.+ 3,280 mm (40 mm increase since 7:00 on September 7)	O.P.+ 3,307 mm (12 mm decrease since 7:00 on September 7)	O.P.+ 3,157 mm (4 mm decrease since 7:00 on September 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,131 mm (Increase from initial level:6,348 mm, 4 mm increase since 7:00 on September 7) O.P.+ 2,228 mm (Increase from initial level:2,954 mm, 208 mm increase since 7:00 on September 7) O.P.+ 4,395 mm (Water level from floor:599 mm, 5 mm increase since 7:00 on September 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:47 on September 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:47 on September 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 7:39 on September 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:24 on September 3 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.