

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 9)**

Water Level of the accumulated water (at 7:00 on September 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,862 mm (674 mm increase since 7:00 on September 8)	O.P.+ 3,120 mm (No change since 7:00 on September 8)	—
	Water level of Turbine Building	O.P.+ 2,629 mm (159 mm increase since 7:00 on September 8)	O.P.+ 3,180 mm (71 mm increase since 7:00 on September 8)	O.P.+ 3,219 mm (33 mm increase since 7:00 on September 8)	O.P.+ 3,184 mm (1 mm increase since 7:00 on September 8)
	Water level of Reactor Building	O.P.+ 5,232 mm (135 mm increase since 7:00 on September 8)	O.P.+ 3,340 mm (60 mm increase since 7:00 on September 8)	O.P.+ 3,371 mm (64 mm increase since 7:00 on September 8)	O.P.+ 3,159 mm (2 mm increase since 7:00 on September 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,148 mm (Increase from initial level:6,365 mm, 17 mm increase since 7:00 on September 8) O.P.+ 2,429 mm (Increase from initial level:3,155 mm, 201 mm increase since 7:00 on September 8) O.P.+ 4,400 mm (Water level from floor:604 mm, 5 mm increase since 7:00 on September 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 14:45 on September 8 to 7:42 on September 9)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 14:45 on September 8 to 7:43 on September 9)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on September 8 to 15:00 on September 8)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 7:39 on September 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:24 on September 3 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.