

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 10)**

Water Level of the accumulated water (at 7:00 on September 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,512 mm (350 mm decrease since 7:00 on September 9)	O.P.+ 3,130 mm (10 mm increase since 7:00 on September 9)	—
	Water level of Turbine Building	O.P.+ 2,884 mm (255 mm increase since 7:00 on September 9)	O.P.+ 3,250 mm (70 mm increase since 7:00 on September 9)	O.P.+ 3,202 mm (17 mm decrease since 7:00 on September 9)	O.P.+ 3,193 mm (9 mm increase since 7:00 on September 9)
	Water level of Reactor Building	O.P.+ 5,207 mm (25 mm decrease since 7:00 on September 9)	O.P.+ 3,409 mm (69 mm increase since 7:00 on September 9)	O.P.+ 3,325 mm (46 mm decrease since 7:00 on September 9)	O.P.+ 3,167 mm (8 mm increase since 7:00 on September 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,080 mm (Increase from initial level:6,297 mm, 68 mm decrease since 7:00 on September 9) O.P.+ 3,009 mm (Increase from initial level:3,735 mm, 580 mm increase since 7:00 on September 9) O.P.+ 4,404 mm (Water level from floor:608 mm, 4 mm increase since 7:00 on September 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:39 on September 9)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:39 on September 9)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on September 9 to 15:00 on September 9)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:26 on September 9 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:22 on September 10 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.