

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 11)**

Water Level of the accumulated water (at 7:00 on September 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,052 mm (540 mm increase since 7:00 on September 10)	O.P.+ 3,160 mm (30 mm increase since 7:00 on September 10)	—
	Water level of Turbine Building	O.P.+ 3,112 mm (228 mm increase since 7:00 on September 10)	O.P.+ 3,261 mm (11 mm increase since 7:00 on September 10)	O.P.+ 3,220 mm (18 mm increase since 7:00 on September 10)	O.P.+ 3,196 mm (3 mm increase since 7:00 on September 10)
	Water level of Reactor Building	O.P.+ 5,248 mm (41 mm increase since 7:00 on September 10)	O.P.+ 3,311 mm (98 mm decrease since 7:00 on September 10)	O.P.+ 3,360 mm (35 mm increase since 7:00 on September 10)	O.P.+ 3,169 mm (2 mm increase since 7:00 on September 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,291 mm (Increase from initial level:6,508 mm, 211 mm increase since 7:00 on September 10) O.P.+ 3,096 mm (Increase from initial level:3,822 mm, 87 mm increase since 7:00 on September 10) O.P.+ 4,407 mm (Water level from floor:611 mm, 3 mm increase since 7:00 on September 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 13:39 on September 9 to 8:19 on September 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 13:39 on September 9 to 8:26 on September 10)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on September 10 to 15:00 on September 10)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:26 on September 9 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:46 on September 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.