

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 13)**

Water Level of the accumulated water (at 7:00 on September 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,043 mm (438 mm increase since 7:00 on September 12)	O.P.+ 3,200 mm (10 mm decrease since 7:00 on September 12)	—
	Water level of Turbine Building	O.P.+ 3,382 mm (23 mm increase since 7:00 on September 12)	O.P.+ 3,355 mm (25 mm increase since 7:00 on September 12)	O.P.+ 3,239 mm (33 mm decrease since 7:00 on September 12)	O.P.+ 3,221 mm (12 mm increase since 7:00 on September 12)
	Water level of Reactor Building	O.P.+ 5,191 mm (10 mm decrease since 7:00 on September 12)	O.P.+ 3,481 mm (27 mm increase since 7:00 on September 12)	O.P.+ 3,369 mm (31 mm decrease since 7:00 on September 12)	O.P.+ 3,185 mm (8 mm increase since 7:00 on September 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,367 mm (Increase from initial level:6,584 mm, 40 mm increase since 7:00 on September 12) O.P.+ 2,780 mm (Increase from initial level:3,506 mm, 12 mm decrease since 7:00 on September 12) O.P.+ 4,413 mm (Water level from floor:617 mm, 3 mm increase since 7:00 on September 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 13:03 on September 12 to 15:07 on September 12)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:58 on September 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:16 on September 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:26 on September 9 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:46 on September 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.