

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 15)**

Water Level of the accumulated water (at 7:00 on September 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,633 mm (265 mm increase since 7:00 on September 14)	O.P.+ 3,200 mm (30 mm decrease since 7:00 on September 14)	—
	Water level of Turbine Building	O.P.+ 3,496 mm (48 mm increase since 7:00 on September 14)	O.P.+ 3,379 mm (13 mm increase since 7:00 on September 14)	O.P.+ 3,242 mm (34 mm decrease since 7:00 on September 14)	O.P.+ 3,232 mm (5 mm increase since 7:00 on September 14)
	Water level of Reactor Building	O.P.+ 5,163 mm (21 mm decrease since 7:00 on September 14)	O.P.+ 3,502 mm (8 mm increase since 7:00 on September 14)	O.P.+ 3,374 mm (33 mm decrease since 7:00 on September 14)	O.P.+ 3,197 mm (8 mm increase since 7:00 on September 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,347 mm (Increase from initial level:6,564 mm, 68 mm increase since 7:00 on September 14) O.P.+ 2,765 mm (Increase from initial level:3,491 mm, 10 mm decrease since 7:00 on September 14) O.P.+ 4,415 mm (Water level from floor:619 mm, 1 mm increase since 7:00 on September 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer suspended (From 16:58 on September 11 to 5:39 on September 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer suspended (From 10:16 on September 12 to 5:32 on September 15)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Unit 6 Condensate Storage Tank	Transfer Completed	(From 10:00 on September 14 to 15:00 on September 14)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:06 on September 14 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:46 on September 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.