

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 17)**

Water Level of the accumulated water (at 7:00 on September 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,055 mm (200 mm increase since 7:00 on September 16)	O.P.+ 3,260 mm (20 mm increase since 7:00 on September 16)	—
	Water level of Turbine Building	O.P.+ 3,412 mm (108 mm decrease since 7:00 on September 16)	O.P.+ 3,295 mm (61 mm decrease since 7:00 on September 16)	O.P.+ 3,313 mm (27 mm increase since 7:00 on September 16)	O.P.+ 3,250 mm (14 mm increase since 7:00 on September 16)
	Water level of Reactor Building	O.P.+ 5,104 mm (28 mm decrease since 7:00 on September 16)	O.P.+ 3,463 mm (14 mm increase since 7:00 on September 16)	O.P.+ 3,455 mm (31 mm increase since 7:00 on September 16)	O.P.+ 3,209 mm (6 mm increase since 7:00 on September 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,397 mm (Increase from initial level:6,614 mm, 175 mm increase since 7:00 on September 16) O.P.+ 2,370 mm (Increase from initial level:3,096 mm, 583 mm decrease since 7:00 on September 16) O.P.+ 4,417 mm (Water level from floor:621 mm, 1 mm increase since 7:00 on September 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 6:02 on September 16 to 10:58 on September 16)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:54 on September 16)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on September 16 to 15:00 on September 16)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:06 on September 14 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:28 on September 17 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.