

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 18)**

Water Level of the accumulated water (at 7:00 on September 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,501 mm (1,554 mm decrease since 7:00 on September 17)	O.P.+ 3,260 mm (No change since 7:00 on September 17)	—
	Water level of Turbine Building	O.P.+ 3,547 mm (135 mm increase since 7:00 on September 17)	O.P.+ 3,285 mm (10 mm decrease since 7:00 on September 17)	O.P.+ 3,372 mm (59 mm increase since 7:00 on September 17)	O.P.+ 3,266 mm (16 mm increase since 7:00 on September 17)
	Water level of Reactor Building	O.P.+ 5,225 mm (121 mm increase since 7:00 on September 17)	O.P.+ 3,296 mm (167 mm decrease since 7:00 on September 17)	O.P.+ 3,542 mm (87 mm increase since 7:00 on September 17)	O.P.+ 3,220 mm (11 mm increase since 7:00 on September 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,320 mm (Increase from initial level:6,537 mm, 77 mm decrease since 7:00 on September 17) O.P.+ 2,705 mm (Increase from initial level:3,431 mm, 335 mm increase since 7:00 on September 17) O.P.+ 4,420 mm (Water level from floor:624 mm, 3 mm increase since 7:00 on September 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
			Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:57 on September 17)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on September 17 to 15:00 on September 17)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:06 on September 14 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:33 on September 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.