

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 19)**

Water Level of the accumulated water (at 7:00 on September 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,984 mm (483 mm increase since 7:00 on September 18)	O.P.+ 3,310 mm (50 mm increase since 7:00 on September 18)	—
	Water level of Turbine Building	O.P.+ 3,224 mm (323 mm decrease since 7:00 on September 18)	O.P.+ 3,222 mm (63 mm decrease since 7:00 on September 18)	O.P.+ 3,376 mm (4 mm increase since 7:00 on September 18)	O.P.+ 3,285 mm (19 mm increase since 7:00 on September 18)
	Water level of Reactor Building	O.P.+ 5,191 mm (34 mm decrease since 7:00 on September 18)	O.P.+ 3,306 mm (10 mm increase since 7:00 on September 18)	O.P.+ 3,529 mm (13 mm decrease since 7:00 on September 18)	O.P.+ 3,228 mm (8 mm increase since 7:00 on September 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,011 mm (Increase from initial level:6,228 mm, 309 mm decrease since 7:00 on September 18) O.P.+ 3,266 mm (Increase from initial level:3,992 mm, 561 mm increase since 7:00 on September 18) O.P.+ 4,423 mm (Water level from floor:627 mm, 3 mm increase since 7:00 on September 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building →Unit 1 Radiation Waste Treatment Building Transfer Completed (From 17:40 on September 18 to 6:02 on September 19)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:57 on September 17)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:30 on September 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 7:34 on September 19 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:33 on September 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.