

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 20)**

Water Level of the accumulated water (at 7:00 on September 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,314 mm (330 mm increase since 7:00 on September 19)	O.P.+ 3,300 mm (10 mm decrease since 7:00 on September 19)	—
	Water level of Turbine Building	O.P.+ 3,275 mm (51 mm increase since 7:00 on September 19)	O.P.+ 3,207 mm (15 mm decrease since 7:00 on September 19)	O.P.+ 3,336 mm (40 mm decrease since 7:00 on September 19)	O.P.+ 3,301 mm (16 mm increase since 7:00 on September 19)
	Water level of Reactor Building	O.P.+ 5,168 mm (23 mm decrease since 7:00 on September 19)	O.P.+ 3,341 mm (35 mm increase since 7:00 on September 19)	O.P.+ 3,493 mm (36 mm decrease since 7:00 on September 19)	O.P.+ 3,237 mm (9 mm increase since 7:00 on September 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,028 mm (Increase from initial level:6,245 mm, 17 mm increase since 7:00 on September 19) O.P.+ 3,395 mm (Increase from initial level:4,121 mm, 129 mm increase since 7:00 on September 19) O.P.+ 4,425 mm (Water level from floor:629 mm, 2 mm increase since 7:00 on September 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:33 on September 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 15:40 on September 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:58 on September 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:33 on September 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.