

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 21)**

Water Level of the accumulated water (at 7:00 on September 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,558 mm (244 mm increase since 7:00 on September 20)	O.P.+ 3,260 mm (40 mm decrease since 7:00 on September 20)	—
	Water level of Turbine Building	O.P.+ 3,157 mm (118 mm decrease since 7:00 on September 20)	O.P.+ 3,191 mm (16 mm decrease since 7:00 on September 20)	O.P.+ 3,293 mm (43 mm decrease since 7:00 on September 20)	O.P.+ 3,299 mm (2 mm decrease since 7:00 on September 20)
	Water level of Reactor Building	O.P.+ 5,136 mm (32 mm decrease since 7:00 on September 20)	O.P.+ 3,332 mm (9 mm decrease since 7:00 on September 20)	O.P.+ 3,443 mm (50 mm decrease since 7:00 on September 20)	O.P.+ 3,245 mm (8 mm increase since 7:00 on September 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,083 mm (Increase from initial level:6,300 mm, 55 mm increase since 7:00 on September 20) O.P.+ 3,226 mm (Increase from initial level:3,952 mm, 169 mm decrease since 7:00 on September 20) O.P.+ 4,427 mm (Water level from floor:631 mm, 2 mm increase since 7:00 on September 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building →Unit 1 Radiation Waste Treatment Building Transfer Completed (From 10:06 on September 20 to 14:54 on September 20)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:33 on September 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 15:40 on September 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:58 on September 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:33 on September 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.