

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 22)**

Water Level of the accumulated water (at 7:00 on September 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,767 mm (209 mm increase since 7:00 on September 21)	O.P.+ 3,240 mm (20 mm decrease since 7:00 on September 21)	—
	Water level of Turbine Building	O.P.+ 3,200 mm (43 mm increase since 7:00 on September 21)	O.P.+ 3,166 mm (25 mm decrease since 7:00 on September 21)	O.P.+ 3,257 mm (36 mm decrease since 7:00 on September 21)	O.P.+ 3,290 mm (9 mm decrease since 7:00 on September 21)
	Water level of Reactor Building	O.P.+ 5,103 mm (33 mm decrease since 7:00 on September 21)	O.P.+ 3,315 mm (17 mm decrease since 7:00 on September 21)	O.P.+ 3,397 mm (46 mm decrease since 7:00 on September 21)	O.P.+ 3,249 mm (4 mm increase since 7:00 on September 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,147 mm (Increase from initial level:6,364 mm, 64 mm increase since 7:00 on September 21) O.P.+ 3,066 mm (Increase from initial level:3,792 mm, 160 mm decrease since 7:00 on September 21) O.P.+ 4,428 mm (Water level from floor:632 mm, 1 mm increase since 7:00 on September 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:33 on September 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 15:40 on September 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:58 on September 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:33 on September 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.