

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 23)**

Water Level of the accumulated water (at 7:00 on September 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,946 mm (179 mm increase since 7:00 on September 22)	O.P.+ 3,210 mm (30 mm decrease since 7:00 on September 22)	—
	Water level of Turbine Building	O.P.+ 3,241 mm (41 mm increase since 7:00 on September 22)	O.P.+ 3,147 mm (19 mm decrease since 7:00 on September 22)	O.P.+ 3,229 mm (28 mm decrease since 7:00 on September 22)	O.P.+ 3,275 mm (15 mm decrease since 7:00 on September 22)
	Water level of Reactor Building	O.P.+ 5,073 mm (30 mm decrease since 7:00 on September 22)	O.P.+ 3,293 mm (22 mm decrease since 7:00 on September 22)	O.P.+ 3,367 mm (30 mm decrease since 7:00 on September 22)	O.P.+ 3,247 mm (2 mm decrease since 7:00 on September 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,207 mm (Increase from initial level:6,424 mm, 60 mm increase since 7:00 on September 22) O.P.+ 2,882 mm (Increase from initial level:3,608 mm, 184 mm decrease since 7:00 on September 22) O.P.+ 4,428 mm (Water level from floor:632 mm, No change since 7:00 on September 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 15:33 on September 19 to 5:31 on September 23)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 15:40 on September 19 to 5:26 on September 23)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:58 on September 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:33 on September 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.