

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 24)**

Water Level of the accumulated water (at 7:00 on September 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,096 mm (150 mm increase since 7:00 on September 23)	O.P.+ 3,210 mm (No change since 7:00 on September 23)	—
	Water level of Turbine Building	O.P.+ 3,071 mm (170 mm decrease since 7:00 on September 23)	O.P.+ 3,158 mm (11 mm increase since 7:00 on September 23)	O.P.+ 3,231 mm (2 mm increase since 7:00 on September 23)	O.P.+ 3,264 mm (11 mm decrease since 7:00 on September 23)
	Water level of Reactor Building	O.P.+ 5,054 mm (19 mm decrease since 7:00 on September 23)	O.P.+ 3,219 mm (74 mm decrease since 7:00 on September 23)	O.P.+ 3,367 mm (No change since 7:00 on September 23)	O.P.+ 3,238 mm (9 mm decrease since 7:00 on September 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,106 mm (Increase from initial level:6,323 mm, 101 mm decrease since 7:00 on September 23) O.P.+ 3,284 mm (Increase from initial level:4,010 mm, 402 mm increase since 7:00 on September 23) O.P.+ 4,429 mm (Water level from floor:633 mm, 1 mm increase since 7:00 on September 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building →Unit 1 Radiation Waste Treatment Building Transfer Completed (From 11:53 on September 23 to 17:48 on September 23)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (From 11:49 on September 23 to 8:39 on September 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (From 11:47 on September 23 to 8:37 on September 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 7:32 on September 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:33 on September 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.