

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 25)**

Water Level of the accumulated water (at 7:00 on September 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,170 mm (1,926 mm decrease since 7:00 on September 24)	O.P.+ 3,210 mm (No change since 7:00 on September 24)	—
	Water level of Turbine Building	O.P.+ 3,230 mm (159 mm increase since 7:00 on September 24)	O.P.+ 3,152 mm (6 mm decrease since 7:00 on September 24)	O.P.+ 3,260 mm (29 mm increase since 7:00 on September 24)	O.P.+ 3,248 mm (16 mm decrease since 7:00 on September 24)
	Water level of Reactor Building	O.P.+ 4,932 mm (122 mm decrease since 7:00 on September 24)	O.P.+ 3,201 mm (18 mm decrease since 7:00 on September 24)	O.P.+ 3,395 mm (28 mm increase since 7:00 on September 24)	O.P.+ 3,224 mm (14 mm decrease since 7:00 on September 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,106 mm (Increase from initial level:6,323 mm, No change since 7:00 on September 24) O.P.+ 3,875 mm (Increase from initial level:4,601 mm, 591 mm increase since 7:00 on September 24) O.P.+ 4,430 mm (Water level from floor:634 mm, 1 mm increase since 7:00 on September 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 14:55 on September 24 to 8:50 on September 25)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on September 24 to 15:00 on September 24)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 7:32 on September 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:33 on September 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.