

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 27)**

Water Level of the accumulated water (at 7:00 on September 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,657 mm (181 mm increase since 7:00 on September 26)	O.P.+ 3,170 mm (20 mm decrease since 7:00 on September 26)	—
	Water level of Turbine Building	O.P.+ 2,713 mm (68 mm decrease since 7:00 on September 26)	O.P.+ 3,096 mm (35 mm decrease since 7:00 on September 26)	O.P.+ 3,197 mm (39 mm decrease since 7:00 on September 26)	O.P.+ 3,234 mm (7 mm decrease since 7:00 on September 26)
	Water level of Reactor Building	O.P.+ 4,900 mm (29 mm increase since 7:00 on September 26)	O.P.+ 3,257 mm (15 mm decrease since 7:00 on September 26)	O.P.+ 3,327 mm (49 mm decrease since 7:00 on September 26)	O.P.+ 3,210 mm (7 mm decrease since 7:00 on September 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,212 mm (Increase from initial level:6,429 mm, 33 mm increase since 7:00 on September 26) O.P.+ 3,591 mm (Increase from initial level:4,317 mm, 117 mm increase since 7:00 on September 26) O.P.+ 4,432 mm (Water level from floor:636 mm, 1 mm increase since 7:00 on September 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building →Unit 1 Radiation Waste Treatment Building Transfer Completed (From 17:58 on September 25 to 9:56 on September 26)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:03 on September 25)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 17:07 on September 25)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:51 on September 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 15:21 on September 26 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.