Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 28)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on September 28)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,795 mm (138 mm increase since 7:00 on September 27)	O.P.+ 3,140 mm (30 mm decrease since 7:00 on September 27)	_
	Water level of Turbine Building	O.P.+ 2,754 mm (41 mm increase since 7:00 on September 27)	O.P.+ 3,056 mm (40 mm decrease since 7:00 on September 27)	O.P.+ 3,165 mm (32 mm decrease since 7:00 on September 27)	O.P.+ 3,230 mm (4 mm decrease since 7:00 on September 27)
	Water level of Reactor Building	O.P.+ 4,913 mm (13 mm increase since 7:00 on September 27)	O.P.+ 3,217 mm (40 mm decrease since 7:00 on September 27)	O.P.+ 3,289 mm (38 mm decrease since 7:00 on September 27)	O.P.+ 3,200 mm (10 mm decrease since 7:00 on September 27)
	Water level of each building in the Centralized Radiation Waste	Process Main Building	O.P.+ 5,244 mm (Increase from initial level:6,461 mm, 32 mm increase since 7:00 on September 27)		
		High Temperature Incinerator Building	O.P.+ 3,318 mm (Increase from initial level:4,044 mm, 273 mm decrease since 7:00 on September 27)		
	Treatment Facility	On-site Bunker Building	O.P.+ 4,433 mm (Water level from floor:637 mm, 2 mm increase since 7:00 on September 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building →Unit 1 Radiation Waste Treatment Building Transfer Completed (From 17:58 on September 25 to 9:56 on September 26)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:03 on September 25)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 17:07 on September 25 to 6:04 on September 28)	_
		Unit 5 and 6			
			_		
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:51 on September 25 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 15:21 on September 26 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

% For quick publication of the data of water level, values are provided as reference values.