

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 1)**

Water Level of the accumulated water (at 7:00 on October 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,100 mm (89 mm increase since 7:00 on September 30)	O.P.+ 3,180 mm (20 mm decrease since 7:00 on September 30)	—
	Water level of Turbine Building	O.P.+ 2,674 mm (145 mm decrease since 7:00 on September 30)	O.P.+ 2,939 mm (39 mm decrease since 7:00 on September 30)	O.P.+ 3,215 mm (42 mm decrease since 7:00 on September 30)	O.P.+ 3,214 mm (3 mm increase since 7:00 on September 30)
	Water level of Reactor Building	O.P.+ 4,896 mm (14 mm decrease since 7:00 on September 30)	O.P.+ 3,108 mm (35 mm decrease since 7:00 on September 30)	O.P.+ 3,356 mm (35 mm decrease since 7:00 on September 30)	O.P.+ 3,194 mm (4 mm increase since 7:00 on September 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,119 mm (Increase from initial level:6,336 mm, 156 mm increase since 7:00 on September 30) O.P.+ 2,644 mm (Increase from initial level:3,370 mm, 192 mm decrease since 7:00 on September 30) O.P.+ 4,437 mm (Water level from floor:641 mm, 1 mm increase since 7:00 on September 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building →Unit 1 Radiation Waste Treatment Building Transfer Completed (From 6:24 on September 30 to 11:50 on September 30)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:03 on September 25)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:17 on September 30)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:43 on September 30 to 15:34 on September 30)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 7:34 on September 30   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:25 on October 1   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.