

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 2)**

Water Level of the accumulated water (at 7:00 on October 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,186 mm (86 mm increase since 7:00 on October 1)	O.P.+ 3,160 mm (20 mm decrease since 7:00 on October 1)	—
	Water level of Turbine Building	O.P.+ 2,711 mm (37 mm increase since 7:00 on October 1)	O.P.+ 2,905 mm (34 mm decrease since 7:00 on October 1)	O.P.+ 3,179 mm (36 mm decrease since 7:00 on October 1)	O.P.+ 3,206 mm (8 mm decrease since 7:00 on October 1)
	Water level of Reactor Building	O.P.+ 4,881 mm (15 mm decrease since 7:00 on October 1)	O.P.+ 3,084 mm (24 mm decrease since 7:00 on October 1)	O.P.+ 3,307 mm (49 mm decrease since 7:00 on October 1)	O.P.+ 3,185 mm (9 mm decrease since 7:00 on October 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,301 mm (Increase from initial level:6,518 mm, 182 mm increase since 7:00 on October 1) O.P.+ 2,615 mm (Increase from initial level:3,341 mm, 29 mm decrease since 7:00 on October 1) O.P.+ 4,437 mm (Water level from floor:641 mm, No change since 7:00 on October 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:03 on September 25)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:17 on September 30)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on October 1 to 15:00 on October 1)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 7:34 on September 30   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:29 on October 1   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.