

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 3)**

Water Level of the accumulated water (at 7:00 on October 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,272 mm (86 mm increase since 7:00 on October 2)	O.P.+ 3,140 mm (20 mm decrease since 7:00 on October 2)	—
	Water level of Turbine Building	O.P.+ 2,748 mm (37 mm increase since 7:00 on October 2)	O.P.+ 2,875 mm (30 mm decrease since 7:00 on October 2)	O.P.+ 3,217 mm (38 mm increase since 7:00 on October 2)	O.P.+ 3,201 mm (5 mm decrease since 7:00 on October 2)
	Water level of Reactor Building	O.P.+ 4,847 mm (34 mm decrease since 7:00 on October 2)	O.P.+ 3,032 mm (52 mm decrease since 7:00 on October 2)	O.P.+ 3,351 mm (44 mm increase since 7:00 on October 2)	O.P.+ 3,178 mm (7 mm decrease since 7:00 on October 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,182 mm (Increase from initial level:6,399 mm, 119 mm decrease since 7:00 on October 2) O.P.+ 2,411 mm (Increase from initial level:3,137 mm, 204 mm decrease since 7:00 on October 2) O.P.+ 4,440 mm (Water level from floor:644 mm, 3 mm increase since 7:00 on October 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:03 on September 25)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 10:17 on September 30 to 10:00 on October 2)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on October 2 to 15:00 on October 2)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:32 on October 2 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:29 on October 1 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.