

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 5)**

Water Level of the accumulated water (at 7:00 on October 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,388 mm (52 mm increase since 7:00 on October 4)	O.P.+ 3,130 mm (30 mm decrease since 7:00 on October 4)	—
	Water level of Turbine Building	O.P.+ 2,592 mm (155 mm decrease since 7:00 on October 4)	O.P.+ 2,804 mm (35 mm decrease since 7:00 on October 4)	O.P.+ 3,143 mm (39 mm decrease since 7:00 on October 4)	O.P.+ 3,188 mm (10 mm decrease since 7:00 on October 4)
	Water level of Reactor Building	O.P.+ 4,771 mm (41 mm decrease since 7:00 on October 4)	O.P.+ 2,963 mm (34 mm decrease since 7:00 on October 4)	O.P.+ 3,273 mm (50 mm decrease since 7:00 on October 4)	O.P.+ 3,169 mm (7 mm decrease since 7:00 on October 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,875 mm (Increase from initial level:6,092 mm, 151 mm decrease since 7:00 on October 4) O.P.+ 3,086 mm (Increase from initial level:3,812 mm, 425 mm increase since 7:00 on October 4) O.P.+ 4,441 mm (Water level from floor:645 mm, No change since 7:00 on October 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building →Unit 1 Radiation Waste Treatment Building Transfer Completed (From 5:51 on October 4 to 12:11 on October 4)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:03 on September 25)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:23 on October 3)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:32 on October 2 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:29 on October 1 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.