

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on October 20,2015)**

Water Level of the accumulated water (at 12:00 on October 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	O.P.+ 2,399 mm (20 mm increase since 7:00 on October 19)	O.P.+ 2,690 mm (29 mm decrease since 7:00 on October 19)	O.P.+ 2,844 mm (18 mm decrease since 7:00 on October 19)	O.P.+ 3,052 mm (16 mm decrease since 7:00 on October 19)
	Water level of Reactor Building	O.P.+ 4,155 mm (53 mm increase since 7:00 on October 19)	O.P.+ 2,793 mm (No change since 7:00 on October 19)	O.P.+ 2,839 mm (19 mm decrease since 7:00 on October 19)	O.P.+ 2,959 mm (10 mm decrease since 7:00 on October 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,079 mm (7 mm increase since 7:00 on October 19) O.P.+ 2,649 mm (162 mm increase since 7:00 on October 19) O.P.+ 4,294 mm (2 mm increase since 7:00 on October 19)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.