

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on November 5,2015)**

Water Level of the accumulated water (at 5:00 on November 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	O.P.+ 2,598 mm (16 mm increase since 12:00 on November 4)	O.P.+ 2,748 mm (1 mm decrease since 12:00 on November 4)	O.P.+ 2,745 mm (16 mm increase since 12:00 on November 4)	O.P.+ 2,905 mm (6 mm decrease since 12:00 on November 4)
	Water level of Reactor Building	O.P.+ 4,095 mm (35 mm increase since 12:00 on November 4)	O.P.+ 2,821 mm (16 mm decrease since 12:00 on November 4)	O.P.+ 2,759 mm (9 mm increase since 12:00 on November 4)	O.P.+ 2,808 mm (6 mm decrease since 12:00 on November 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,315 mm (7 mm increase since 12:00 on November 4) O.P.+ 2,177 mm (99 mm decrease since 12:00 on November 4) O.P.+ 4,326 mm (2 mm increase since 12:00 on November 4)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.