

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 12:00 on November 6,2015)**

Water Level of the accumulated water (at 12:00 on November 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,173 mm (22 mm increase since 5:00 on November 5)	T.P.+ 1,369 mm (50 mm increase since 5:00 on November 5)	T.P.+ 1,357 mm (31 mm increase since 5:00 on November 5)	T.P.+ 1,465 mm (No change since 5:00 on November 5)
	Water level of Reactor Building	T.P.+ 2,723 mm (41 mm increase since 5:00 on November 5)	T.P.+ 1,438 mm (40 mm increase since 5:00 on November 5)	T.P.+ 1,377 mm (35 mm increase since 5:00 on November 5)	T.P.+ 1,367 mm (2 mm decrease since 5:00 on November 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building  High Temperature Incinerator Building  On-site Bunker Building	T.P.+ 960 mm (3 mm increase since 5:00 on November 5)  T.P.+ 721 mm ( 3 mm increase since 5:00 on November 5)  T.P.+ 2,892 mm (3 mm increase since 5:00 on November 5)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.