

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 12:00 on November 7,2015)**

Water Level of the accumulated water (at 12:00 on November 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,196 mm (23 mm increase since 5:00 on November 6)	T.P.+ 1,444 mm (75 mm increase since 5:00 on November 6)	T.P.+ 1,383 mm (26 mm increase since 5:00 on November 6)	T.P.+ 1,471 mm (6 mm increase since 5:00 on November 6)
	Water level of Reactor Building	T.P.+ 2,767 mm (44 mm increase since 5:00 on November 6)	T.P.+ 1,503 mm (65 mm increase since 5:00 on November 6)	T.P.+ 1,398 mm (21 mm increase since 5:00 on November 6)	T.P.+ 1,371 mm (4 mm increase since 5:00 on November 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 963 mm (3 mm increase since 5:00 on November 6) T.P.+ 734 mm ( 13 mm increase since 5:00 on November 6) T.P.+ 2,894 mm (2 mm increase since 5:00 on November 6)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.