

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on November 10,2015)**

Water Level of the accumulated water (at 12:00 on November 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,134 mm (27 mm increase since 12:00 on November 9)	T.P.+ 1,677 mm (76 mm increase since 12:00 on November 9)	T.P.+ 1,444 mm (21 mm increase since 12:00 on November 9)	T.P.+ 1,507 mm (13 mm increase since 12:00 on November 9)
	Water level of Reactor Building	T.P.+ 2,945 mm (66 mm increase since 12:00 on November 9)	T.P.+ 1,742 mm (75 mm increase since 12:00 on November 9)	T.P.+ 1,462 mm (19 mm increase since 12:00 on November 9)	T.P.+ 1,389 mm (5 mm increase since 12:00 on November 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 971 mm (2 mm increase since 12:00 on November 9) T.P.+ 736 mm (1 mm increase since 12:00 on November 9) T.P.+ 2,903 mm (4 mm increase since 12:00 on November 9)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.