

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on December 4,2015)**

Water Level of the accumulated water (at 12:00 on December 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,196 mm (36 mm increase since 12:00 on December 3)	T.P.+ 1,515 mm (14 mm increase since 12:00 on December 3)	T.P.+ 1,559 mm (41 mm decrease since 12:00 on December 3)	T.P.+ 1,665 mm (5 mm increase since 12:00 on December 3)
	Water level of Reactor Building	T.P.+ 2,155 mm (12 mm decrease since 12:00 on December 3)	T.P.+ 1,596 mm (7 mm increase since 12:00 on December 3)	T.P.+ 1,581 mm (40 mm decrease since 12:00 on December 3)	T.P.+ 1,530 mm (6 mm increase since 12:00 on December 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 3,294 mm (2 mm decrease since 12:00 on December 3) T.P.+ 1,222 mm (1,077 mm increase since 12:00 on December 3) T.P.+ 2,950 mm (1 mm increase since 12:00 on December 3)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.