

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on December 5,2015)**

Water Level of the accumulated water (at 12:00 on December 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,229 mm (33 mm increase since 12:00 on December 4)	T.P.+ 1,514 mm (1 mm decrease since 12:00 on December 4)	T.P.+ 1,587 mm (28 mm increase since 12:00 on December 4)	T.P.+ 1,669 mm (4 mm increase since 12:00 on December 4)
	Water level of Reactor Building	T.P.+ 2,206 mm (51 mm increase since 12:00 on December 4)	T.P.+ 1,589 mm (7 mm decrease since 12:00 on December 4)	T.P.+ 1,595 mm (14 mm increase since 12:00 on December 4)	T.P.+ 1,534 mm (4 mm increase since 12:00 on December 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 3,298 mm (4 mm increase since 12:00 on December 4) T.P.+ 1,767 mm (545 mm increase since 12:00 on December 4) T.P.+ 2,952 mm (2 mm increase since 12:00 on December 4)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.