

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on December 9,2015)**

Water Level of the accumulated water (at 12:00 on December 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,072 mm (34 mm increase since 12:00 on December 8)	T.P.+ 1,581 mm (101 mm increase since 12:00 on December 8)	T.P.+ 1,652 mm (14 mm increase since 12:00 on December 8)	T.P.+ 1,709 mm (12 mm increase since 12:00 on December 8)
	Water level of Reactor Building	T.P.+ 2,158 mm (37 mm decrease since 12:00 on December 8)	T.P.+ 1,626 mm (70 mm increase since 12:00 on December 8)	T.P.+ 1,670 mm (23 mm increase since 12:00 on December 8)	T.P.+ 1,564 mm (9 mm increase since 12:00 on December 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 3,304 mm (4 mm increase since 12:00 on December 8) T.P.+ 981 mm (522 mm decrease since 12:00 on December 8) T.P.+ 2,961 mm (3 mm increase since 12:00 on December 8)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.