

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 12:00 on December 11,2015)**

Water Level of the accumulated water (at 12:00 on December 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,135 mm (31 mm increase since 12:00 on December 10)	T.P.+ 1,601 mm (4 mm increase since 12:00 on December 10)	T.P.+ 1,642 mm (33 mm increase since 12:00 on December 10)	T.P.+ 1,726 mm (10 mm increase since 12:00 on December 10)
	Water level of Reactor Building	T.P.+ 2,216 mm (37 mm increase since 12:00 on December 10)	T.P.+ 1,680 mm (14 mm increase since 12:00 on December 10)	T.P.+ 1,675 mm (35 mm increase since 12:00 on December 10)	T.P.+ 1,580 mm (7 mm increase since 12:00 on December 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building  High Temperature Incinerator Building  On-site Bunker Building	T.P.+ 3,310 mm (3 mm increase since 12:00 on December 10)  T.P.+ 1,218 mm ( 41 mm decrease since 12:00 on December 10)  T.P.+ 2,965 mm (2 mm increase since 12:00 on December 10)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.