

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on December 15,2015)**

Water Level of the accumulated water (at 12:00 on December 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,147 mm (35 mm increase since 12:00 on December 14)	T.P.+ 1,717 mm (24 mm increase since 12:00 on December 14)	T.P.+ 1,719 mm (14 mm increase since 12:00 on December 14)	T.P.+ 1,776 mm (12 mm increase since 12:00 on December 14)
	Water level of Reactor Building	T.P.+ 2,227 mm (79 mm increase since 12:00 on December 14)	T.P.+ 1,782 mm (23 mm increase since 12:00 on December 14)	T.P.+ 1,731 mm (15 mm increase since 12:00 on December 14)	T.P.+ 1,614 mm (10 mm increase since 12:00 on December 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 3,493 mm (177 mm increase since 12:00 on December 14) T.P.+ 1,236 mm (46 mm increase since 12:00 on December 14) T.P.+ 2,975 mm (1 mm increase since 12:00 on December 14)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.