

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on January 4,2016)**

Water Level of the accumulated water (at 12:00 on January 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,037 mm (39 mm decrease since 12:00 on January 3)	T.P.+ 1,575 mm (No change since 12:00 on January 3)	T.P.+ 1,660 mm (6 mm decrease since 12:00 on January 3)	T.P.+ 1,742 mm (No change since 12:00 on January 3)
	Water level of Reactor Building	T.P.+ 2,016 mm (50 mm increase since 12:00 on January 3)	T.P.+ 1,668 mm (3 mm decrease since 12:00 on January 3)	T.P.+ 1,661 mm (10 mm increase since 12:00 on January 3)	T.P.+ 1,633 mm (2 mm increase since 12:00 on January 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 3,821 mm (1 mm increase since 12:00 on January 3) T.P.+ 1,127 mm (59 mm increase since 12:00 on January 3) T.P.+ 2,779 mm (4 mm increase since 12:00 on January 3)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.