

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on January 5,2016)**

Water Level of the accumulated water (at 12:00 on January 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,064 mm (27 mm increase since 12:00 on January 4)	T.P.+ 1,565 mm (10 mm decrease since 12:00 on January 4)	T.P.+ 1,673 mm (13 mm increase since 12:00 on January 4)	T.P.+ 1,742 mm (No change since 12:00 on January 4)
	Water level of Reactor Building	T.P.+ 1,816 mm (200 mm decrease since 12:00 on January 4)	T.P.+ 1,657 mm (11 mm decrease since 12:00 on January 4)	T.P.+ 1,656 mm (5 mm decrease since 12:00 on January 4)	T.P.+ 1,630 mm (3 mm decrease since 12:00 on January 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 3,823 mm (2 mm increase since 12:00 on January 4) T.P.+ 1,377 mm (250 mm increase since 12:00 on January 4) T.P.+ 2,781 mm (2 mm increase since 12:00 on January 4)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.