

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on May 5,2016)**

Water Level of the accumulated water (at 12:00 on May 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,200 mm (23 mm increase since 12:00 on May 4)	T.P.+ 1,339 mm (39 mm increase since 12:00 on May 4)	T.P.+ 1,329 mm (37 mm increase since 12:00 on May 4)	T.P.+ 1,482 mm (6 mm decrease since 12:00 on May 4)
	Water level of Reactor Building	T.P.+ 1,444 mm (7 mm decrease since 12:00 on May 4)	T.P.+ 1,422 mm (No change since 12:00 on May 4)	T.P.+ 1,339 mm (12 mm increase since 12:00 on May 4)	T.P.+ 1,377 mm (6 mm decrease since 12:00 on May 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,673 mm (No change since 12:00 on May 4) T.P.+ -5 mm (287 mm decrease since 12:00 on May 4) T.P.+ 2,755 mm (9 mm increase since 12:00 on May 4)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.