

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on June 3,2016)**

Water Level of the accumulated water (at 12:00 on June 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,240 mm (21 mm increase since 12:00 on June 2)	T.P.+ 1,413 mm (24 mm decrease since 12:00 on June 2)	T.P.+ 1,253 mm (36 mm decrease since 12:00 on June 2)	T.P.+ 1,459 mm (4 mm decrease since 12:00 on June 2)
	Water level of Reactor Building	T.P.+ 1,483 mm (13 mm increase since 12:00 on June 2)	T.P.+ 1,515 mm (7 mm increase since 12:00 on June 2)	T.P.+ 1,278 mm (8 mm decrease since 12:00 on June 2)	T.P.+ 1,352 mm (4 mm decrease since 12:00 on June 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 1,538 mm (2 mm increase since 12:00 on June 2) T.P.+ 166 mm (221 mm increase since 12:00 on June 2) T.P.+ 2,836 mm (13 mm increase since 12:00 on June 2)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.