

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on June 5,2016)**

Water Level of the accumulated water (at 12:00 on June 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,279 mm (20 mm increase since 12:00 on June 4)	T.P.+ 1,432 mm (54 mm increase since 12:00 on June 4)	T.P.+ 1,278 mm (37 mm increase since 12:00 on June 4)	T.P.+ 1,446 mm (5 mm decrease since 12:00 on June 4)
	Water level of Reactor Building	T.P.+ 1,417 mm (11 mm decrease since 12:00 on June 4)	T.P.+ 1,512 mm (21 mm increase since 12:00 on June 4)	T.P.+ 1,283 mm (30 mm increase since 12:00 on June 4)	T.P.+ 1,342 mm (5 mm decrease since 12:00 on June 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 1,545 mm (4 mm increase since 12:00 on June 4) T.P.+ 47 mm (368 mm decrease since 12:00 on June 4) T.P.+ 2,862 mm (14 mm increase since 12:00 on June 4)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.