

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 12:00 on July 3,2016)**

Water Level of the accumulated water (at 12:00 on July 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,226 mm (29 mm increase since 12:00 on July 2)	T.P.+ 1,429 mm (15 mm decrease since 12:00 on July 2)	T.P.+ 1,397 mm (22 mm increase since 12:00 on July 2)	T.P.+ 1,459 mm (6 mm increase since 12:00 on July 2)
	Water level of Reactor Building	T.P.+ 1,429 mm (13 mm decrease since 12:00 on July 2)	T.P.+ 1,547 mm (5 mm decrease since 12:00 on July 2)	T.P.+ 1,404 mm (24 mm increase since 12:00 on July 2)	T.P.+ 1,322 mm (No change since 12:00 on July 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building  High Temperature Incinerator Building  On-site Bunker Building	T.P.+ 692 mm (21 mm increase since 12:00 on July 2)  T.P.+ 818 mm ( 65 mm decrease since 12:00 on July 2)  T.P.+ 2,683 mm (40 mm decrease since 12:00 on July 2)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.