

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 12:00 on July 5,2016)**

Water Level of the accumulated water (at 12:00 on July 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,152 mm (27 mm increase since 12:00 on July 4)	T.P.+ 1,420 mm (18 mm decrease since 12:00 on July 4)	T.P.+ 1,407 mm (22 mm increase since 12:00 on July 4)	T.P.+ 1,476 mm (8 mm increase since 12:00 on July 4)
	Water level of Reactor Building	T.P.+ 1,457 mm (9 mm increase since 12:00 on July 4)	T.P.+ 1,527 mm (14 mm decrease since 12:00 on July 4)	T.P.+ 1,368 mm (28 mm decrease since 12:00 on July 4)	T.P.+ 1,324 mm (1 mm increase since 12:00 on July 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 696 mm (1 mm increase since 12:00 on July 4) T.P.+ 913 mm ( 26 mm decrease since 12:00 on July 4) T.P.+ 2,683 mm (No change since 12:00 on July 4)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.