

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 12:00 on July 7,2016)**

Water Level of the accumulated water (at 12:00 on July 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,206 mm (28 mm increase since 12:00 on July 6)	T.P.+ 1,412 mm (5 mm increase since 12:00 on July 6)	T.P.+ 1,449 mm (21 mm increase since 12:00 on July 6)	T.P.+ 1,497 mm (10 mm increase since 12:00 on July 6)
	Water level of Reactor Building	T.P.+ 1,495 mm (43 mm increase since 12:00 on July 6)	T.P.+ 1,513 mm (11 mm decrease since 12:00 on July 6)	T.P.+ 1,406 mm (17 mm increase since 12:00 on July 6)	T.P.+ 1,326 mm (No change since 12:00 on July 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building  High Temperature Incinerator Building  On-site Bunker Building	T.P.+ 701 mm (3 mm increase since 12:00 on July 6)  T.P.+ 944 mm ( 40 mm increase since 12:00 on July 6)  T.P.+ 2,692 mm (6 mm increase since 12:00 on July 6)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.