

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on July 31,2016)**

| Water Level of the accumulated water (at 12:00 on July 31) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
|--|--|---|---|---|--|
| | Water level of Turbine Building | T.P.+ 1,323 mm (No change since 12:00 on July 30) | T.P.+ 1,414 mm (39 mm increase since 12:00 on July 30) | T.P.+ 1,444 mm (32 mm increase since 12:00 on July 30) | T.P.+ 1,525 mm (7 mm decrease since 12:00 on July 30) |
| | Water level of Reactor Building | T.P.+ 1,431 mm (18 mm increase since 12:00 on July 30) | T.P.+ 1,512 mm (7 mm increase since 12:00 on July 30) | T.P.+ 1,399 mm (9 mm increase since 12:00 on July 30) | T.P.+ 1,385 mm (2 mm decrease since 12:00 on July 30) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | T.P.+ -336 mm (4 mm increase since 12:00 on July 30) T.P.+ -216 mm (397 mm decrease since 12:00 on July 30) T.P.+ 2,867 mm (11 mm increase since 12:00 on July 30) | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.