

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 12:00 on August 2,2016)**

|   | Unit 1   | Unit 2  | Unit 3  | Unit 4   |   |
|---|--|---|---|--|---|
| Water Level of the accumulated water (at 12:00 on August 2) | Water level of Turbine Building  | T.P.+ 1,240 mm<br>(21 mm increase since 12:00 on August 1)                                | T.P.+ 1,398 mm<br>(6 mm decrease since 12:00 on August 1)   | T.P.+ 1,367 mm<br>(39 mm decrease since 12:00 on August 1) | T.P.+ 1,519 mm<br>(2 mm decrease since 12:00 on August 1) |
|   | Water level of Reactor Building  | T.P.+ 1,413 mm<br>(9 mm decrease since 12:00 on August 1)                                 | T.P.+ 1,513 mm<br>(6 mm decrease since 12:00 on August 1)   | T.P.+ 1,345 mm<br>(38 mm decrease since 12:00 on August 1) | T.P.+ 1,388 mm<br>(No change since 12:00 on August 1)     |
|   | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building | T.P.+ -326 mm (5 mm increase since 12:00 on August 1)<br>T.P.+ 125 mm ( 189 mm increase since 12:00 on August 1)<br>T.P.+ 2,890 mm (12 mm increase since 12:00 on August 1) |  |   |
| Notes   |  |   |   |  |   |

※ For quick publication of the data of water level, values are provided as reference values.