

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on August 3,2016)**

Water Level of the accumulated water (at 12:00 on August 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,259 mm (19 mm increase since 12:00 on August 2)	T.P.+ 1,389 mm (9 mm decrease since 12:00 on August 2)	T.P.+ 1,360 mm (7 mm decrease since 12:00 on August 2)	T.P.+ 1,512 mm (7 mm decrease since 12:00 on August 2)
	Water level of Reactor Building	T.P.+ 1,413 mm (No change since 12:00 on August 2)	T.P.+ 1,506 mm (7 mm decrease since 12:00 on August 2)	T.P.+ 1,319 mm (26 mm decrease since 12:00 on August 2)	T.P.+ 1,388 mm (No change since 12:00 on August 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ -323 mm (3 mm increase since 12:00 on August 2) T.P.+ 216 mm (91 mm increase since 12:00 on August 2) T.P.+ 2,902 mm (12 mm increase since 12:00 on August 2)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.