

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on August 7,2016)**

Water Level of the accumulated water (at 12:00 on August 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,315 mm (3 mm decrease since 12:00 on August 6)	T.P.+ 1,381 mm (No change since 12:00 on August 6)	T.P.+ 1,469 mm (34 mm increase since 12:00 on August 6)	T.P.+ 1,486 mm (7 mm decrease since 12:00 on August 6)
	Water level of Reactor Building	T.P.+ 1,429 mm (8 mm increase since 12:00 on August 6)	T.P.+ 1,503 mm (19 mm decrease since 12:00 on August 6)	T.P.+ 1,338 mm (32 mm increase since 12:00 on August 6)	T.P.+ 1,369 mm (5 mm decrease since 12:00 on August 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ -307 mm (4 mm increase since 12:00 on August 6) T.P.+ -61 mm (283 mm decrease since 12:00 on August 6) T.P.+ 2,950 mm (12 mm increase since 12:00 on August 6)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.