

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on August 10,2016)**

Water Level of the accumulated water (at 12:00 on August 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,251 mm (17 mm increase since 12:00 on August 9)	T.P.+ 1,380 mm (14 mm increase since 12:00 on August 9)	T.P.+ 1,442 mm (4 mm decrease since 12:00 on August 9)	T.P.+ 1,475 mm (6 mm decrease since 12:00 on August 9)
	Water level of Reactor Building	T.P.+ 1,468 mm (40 mm increase since 12:00 on August 9)	T.P.+ 1,491 mm (7 mm decrease since 12:00 on August 9)	T.P.+ 1,324 mm (2 mm increase since 12:00 on August 9)	T.P.+ 1,362 mm (5 mm decrease since 12:00 on August 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ -296 mm (3 mm increase since 12:00 on August 9) T.P.+ -48 mm (12 mm increase since 12:00 on August 9) T.P.+ 2,988 mm (13 mm increase since 12:00 on August 9)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.