

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on September 3,2016)**

Water Level of the accumulated water (at 12:00 on September 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,463 mm (33 mm decrease since 12:00 on September 2)	T.P.+ 1,450 mm (12 mm increase since 12:00 on September 2)	T.P.+ 1,534 mm (41 mm increase since 12:00 on September 2)	T.P.+ 1,435 mm (3 mm decrease since 12:00 on September 2)
	Water level of Reactor Building	T.P.+ 1,461 mm (11 mm decrease since 12:00 on September 2)	T.P.+ 1,568 mm (16 mm increase since 12:00 on September 2)	T.P.+ 1,298 mm (34 mm increase since 12:00 on September 2)	T.P.+ 1,330 mm (1 mm increase since 12:00 on September 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 995 mm (47 mm increase since 12:00 on September 2) T.P.+ 1,391 mm (204 mm increase since 12:00 on September 2) T.P.+ 2,775 mm (211 mm decrease since 12:00 on September 2)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.