

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on September 4,2016)**

Water Level of the accumulated water (at 12:00 on September 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,288 mm (175 mm decrease since 12:00 on September 3)	T.P.+ 1,451 mm (1 mm increase since 12:00 on September 3)	T.P.+ 1,508 mm (26 mm decrease since 12:00 on September 3)	T.P.+ 1,435 mm (No change since 12:00 on September 3)
	Water level of Reactor Building	T.P.+ 1,452 mm (9 mm decrease since 12:00 on September 3)	T.P.+ 1,575 mm (7 mm increase since 12:00 on September 3)	T.P.+ 1,284 mm (14 mm decrease since 12:00 on September 3)	T.P.+ 1,334 mm (4 mm increase since 12:00 on September 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 1,383 mm (388 mm increase since 12:00 on September 3) T.P.+ 1,039 mm (352 mm decrease since 12:00 on September 3) T.P.+ 2,719 mm (56 mm decrease since 12:00 on September 3)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.