

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on September 5,2016)**

Water Level of the accumulated water (at 12:00 on September 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,254 mm (34 mm decrease since 12:00 on September 4)	T.P.+ 1,445 mm (6 mm decrease since 12:00 on September 4)	T.P.+ 1,546 mm (38 mm increase since 12:00 on September 4)	T.P.+ 1,434 mm (1 mm decrease since 12:00 on September 4)
	Water level of Reactor Building	T.P.+ 1,456 mm (4 mm increase since 12:00 on September 4)	T.P.+ 1,571 mm (4 mm decrease since 12:00 on September 4)	T.P.+ 1,299 mm (15 mm increase since 12:00 on September 4)	T.P.+ 1,349 mm (15 mm increase since 12:00 on September 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 1,431 mm (48 mm increase since 12:00 on September 4) T.P.+ 1,097 mm (58 mm increase since 12:00 on September 4) T.P.+ 2,725 mm (6 mm increase since 12:00 on September 4)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.